

NATIONAL INSTITUTE OF PUBLIC HEALTH – NATIONAL INSTITUTE OF HYGIENE

24 Chocimska 00-791 Warsaw – Phone (22)5421354; (22)5421349 – Fax (22) 5421287 – e-mail: sek-zhk@pzh.gov.pl

HYGIENIC CERTIFICATE NO. HK/B/0098/01/2014

Product: **Sandwich panel in metal plates with mineral wool core – BALEXTHERM MW**

Containing: mineral wool, steel, coating: polyester/zinc/PVDF/PVC

Destined: used for construction of external and internal walls of building structures for the following facilities: industry, food, production, sports, office, commercial, services, administrative, public utility, health care (except for surgery rooms and intensive care units)

The product specified above meets the hygienic criteria when the following conditions are fulfilled:

In case of using the product in health care facilities, it has to meet the requirements of the Regulation of the Minister of Health dated June 26, 2012 (Journal of Laws no. 2012.739 dated June 29, 2012) on detailed requirements for the premises and equipment of entities conducting medical activity.

Utilisation of mineral wool in the above products cannot result in its fibres being released to the air in the premises. In case of panels with PVC plates, it is recommended that in the premises where people are constantly present, the coverage with this material does not exceed 50% of all construction areas.

Producer:
BALEX METAL Sp. z o.o.
84-239 Bolszewo
Ul. Wejherowska 12C

This certificate is issued for:
BALEX METAL Sp. z o.o.
84-239 Bolszewo
Ul. Wejherowska 12C

**The certificate may be corrected or cancelled after appropriate motivation.
The certificate loses its validity after 2019-02-21
Or in case of changes in composition or in technology of production.**

The date of issue of the certificate: 21st February 2014

Manager of hygiene institute
Garbas - on behalf of dr Bożena Krogulska

